



BHARUCH DISTRICT LABORATORY  
Gujarat Water Supply Sewerage Board  
BHARUCH



REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER

Name & Address

Narmada Calorx Public School Bharuch  
Survey No. 52, Chavaj Road  
Post : Vadadla

Sender's Ref. No. : Nil/dt.16.09.2020

Ref. Date : 16.09.2020

Date & Time of Commencing Examination : 16.09.2020

Sample collected by : Customer

BW No.	16†
Date of Collection	16.09.2020
Date of Arrival at Lab.	16.09.2020
Source of Water Sample	At Sender's Address
Village	Vadadla
Habitation	Vadadla
Taluka	Bharuch
District	Bharuch
APHA, AWWA, 9221-D Presence - Absence Coliform Test, @ 37° C	A
APHA, AWWA, 9221-F Presence - Absence E-Coli Test, @ 37° C	.....
MPN of coliform per 100 ml of sample at 37° C	<2
MPN of Faecal coliform per 100 ml of sample at 44° C	<2
Free Chlorine ( PPM )	Nil
OPINION FOR POTABILITY :	FIT

Important Note:-

1) '>=' Indicates greater than or equal to, 2) '<' Indicates less than

**NOTE : Table - 6 Bacteriological Quality of Drinking Water (BIS:10500:2012) : Second Revision.**

@ All Water Intended for Drinking -

(a) E.coli or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample.

@ Treated Water Entering the Distribution system & Treated Water in the Distribution system -

(a) E.coli or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample.

(b) Total coliform bacteria shall not be detectable in any 100ml sample.

@ 0.2ppm Free Residual Chlorine at consumer end is recommended.

1) Test Report is issued for assessing Bacteriological Fitness as per the BIS 10500:2012 for the given Drinking Water Sample only.

2) This Report should not be taken as a basis to getting license from any Government authority.

3) After Collection of Bact. Sample, it must be preserved at 4°C and submitted to laboratory within 24hrs.

Outward No.: BAR / 45 / of 2020, Date: 22 / 9 / 2020

Laboratory In charge

*A.N. Parikh*